

## **ADDENDUM # 1**

**August 26, 2010**

The following changes are made to the drawings/Specifications and are considered to be a part of the Bid Documents:

1. Drawings:
  - A. FP-3, FP-4, FP-5 and FP-6 are amended as below:
    - i. Revised sprinkler layout around Atrium area. See attached Sketches SK-FP-1, SK-FP-2, SK-FP-3 and SK-FP-4.
  - B. M-27 is amended as below:
    - i. The refrigerant for AC Units (AC-1, AC-2 and AC-3) shall be R-410A.
2. Specifications:
  - A. Section 15600:
    1. Revised Item 3.03.B
    2. Added Item 3.03.E
    2. Revised Item 3.04.C
    3. Deleted Item 3.04.D and E
    4. Added Item 3.05 – Maintenance and Start-up Beyond Initial Start-up.
    5. See attached revised pages 15600-10 and 11.
  - B. Section 15900:
    1. Revised Item 1.01.A, 1.01.C, 1.03.A.4, 1.04.B, 1.05.A, 1.07.A, 1.07.D, 2.01.D, 3.09.J.1
    2. Added Item 3.07.C and 3.09.B.16.
    3. Delete Section 15900 from Bid Set and use the attached revised Section 15900.

**END OF ADDENDUM # 1**